

Issue Date: 06-21-2019
Revision Date: 06-12-2025
Renewal Date: 06-30-2026

DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION
Section: 07 30 05 – Roofing Felt and Underlayment

REPORT HOLDER:

System Components Corporation
10 West Streetsboro St. #207
Hudson, OH 44236
330-528-0255

<https://systemcomponents.net>

REPORT SUBJECT:

CoverPro® 1000, CoverPro® 2000, CoverPro® 3000,
FelTex®, and FelTex® SA300 Synthetic Roofing
Underlayments

1.0 SCOPE OF EVALUATION

1.1 This Research Report addresses compliance with the following Codes:

- 2021, 2018, and 2015, *International Building Code*® (IBC)
- 2021, 2018, and 2015, *International Residential Code*® (IRC)

NOTE: This report references 2021 Code sections. Earlier version of the Codes may have different section numbers.

1.2 CoverPro® 1000, CoverPro® 2000, CoverPro® 3000, FelTex®, and FelTex® SA300 Synthetic Roofing Underlayments have been evaluated for the following properties (see Table 1):

- Physical properties
- Ice barrier
- Fire classification

1.3 The CoverPro® 1000, CoverPro® 2000, CoverPro® 3000, and FelTex® underlayments have been evaluated for the following uses (see Table 1):

- Use in the field of the roof as an alternative to the ASTM D226, Type I and Type II, roof underlayments

specified in Chapter 15 of the IBC and Chapter 9 of the IRC.

- Use in areas of the roof required by IBC Section 1507 or IRC Section R905 to have an ice barrier roof underlayment, when installed as noted in Section 5.2.
- Use as a component of classified assemblies when installed as noted in Section 4.1.

1.4 The FelTex® SA300 underlayment has been evaluated for the following uses (see Table 1):

- Use in the field of the roof as an alternative to the ASTM D1970 and ASTM D226, Type I and Type II, roof underlayments specified in Chapter 15 of the IBC and Chapter 9 of the IRC.
- Use in areas of the roof required by IBC Section 1507 or IRC Section R905 to have an ice barrier roof underlayment, when installed as noted in Section 5.2.2.

2.0 STATEMENT OF COMPLIANCE

CoverPro® 1000, CoverPro® 2000, CoverPro® 3000, FelTex®, and FelTex® SA300 Synthetic Roofing Underlayments comply with the Codes listed in Section 1.1, for the properties stated in Section 1.2, and uses stated in Section 1.3, when installed as described in this report, including the Conditions of Use stated in Section 6.0.

3.0 DESCRIPTION

3.1 **CoverPro® 1000** is a mechanically attached synthetic roofing underlayment comprised of a non-woven polymeric top scrim laminated onto a cross-woven bottom scrim. The underlayment has an overall nominal weight of 1.74 pounds per 100 square feet. The underlayment is available in rolls of 40, 60, and 120 inches wide by 300 feet long. Other sizes are available upon request.

3.2 **CoverPro® 2000** is a mechanically attached synthetic roofing underlayment comprised of a non-woven polymeric top scrim laminated onto a cross-woven



bottom scrim. The bottom side of the cross-woven scrim is coated with elastomeric material. The underlayment has an overall nominal weight of 1.97 pounds per 100 square feet. The underlayment is available in rolls of 40, 60, and 120 inches wide by 300 feet long. Other sizes are available upon request.

3.3 CoverPro® 3000 is a mechanically attached synthetic roofing underlayment comprised of a woven polypropylene scrim laminated to a non-woven polypropylene scrim. The underlayment is coated on the exposed side. The underlayment has an overall nominal weight of 2.5 pounds per 100 square feet. The underlayment is available in rolls of 40, 60, and 120 inches wide by 300 feet long. Other sizes are available upon request.

3.4 FelTex® is a mechanically attached synthetic roofing underlayment comprised of a cross-woven polypropylene scrim with two-ply proprietary coating on the exposed side. The underlayment has an overall nominal weight of 2.9 pounds per 100 square feet. The underlayment is available in rolls of 48 and 96 inches wide by 250 feet long. Other sizes are available upon request.

3.5 FelTex® SA300 is a self-adhered synthetic roofing underlayment comprised of a cross-woven polypropylene facer, adhesive membrane, and a release liner. The underlayment has an overall nominal weight of 9.4 pounds per 100 square feet. The underlayment is available in rolls of 48 inches wide by 53.3 feet long. Other sizes are available upon request.

4.0 PERFORMANCE CHARACTERISTICS

4.1 Fire Classification: The CoverPro® 1000, CoverPro® 2000, CoverPro® 3000, and FelTex® Synthetic Roofing Underlayments may be used as a component of a classified roof assembly when specifically recognized as such in a Listing approved by the Code official. The underlayments may also be used as an alternative to the underlayments specified in the Code for roof coverings permitted under the Exceptions to IBC Section 1505.2 and IRC Section R902.1 and may be used where non-classified roofing is permitted in IBC Section 1505.5.

5.0 INSTALLATION

5.1 General: CoverPro® 1000, CoverPro® 2000, CoverPro® 3000, FelTex®, and FelTex® SA300 Synthetic Roofing Underlayments must be installed in accordance with the manufacturer's published installation instructions, the applicable Code, and this Research Report. A copy of the manufacturer's instructions must be available on the jobsite during installation.

The underlayments must be installed in accordance with the subsections of IBC Section 1507 and IRC Section R905 applicable to the roof covering being installed. The underlayments must be laid with the print side up with laps as required by the applicable Code, evaluation report, or manufacturer's instructions, whichever is more restrictive.

The roof covering may be installed immediately following the underlayment application, and the underlayment must be covered within the time designated in the report holder's published installation instructions.

5.2 Ice Barrier:

5.2.1 Mechanically Attached Roofing Underlayments:

In areas of the roof required by IBC Section 1507 or IRC Section R905 to have an ice barrier, two layers of the CoverPro® 1000, CoverPro® 2000, CoverPro® 3000, and FelTex® Synthetic Roofing Underlayments, solidly cemented together with a low solvent-based roofing cement complying with ASTM D4586 Type 1 (asbestos free), may be used provided the ice barrier extends up the roof a minimum distance of 24 inches inside the interior wall line of the building. The underlayments installed in the field of the roof must overlap the ice barrier.

5.2.2 FelTex® SA300 Self-adhered Roofing Underlayment:

The roof deck must be in proper condition to ensure proper adhesion. Installation is limited to plywood or oriented strand board (OSB) substrates. The FelTex® SA300 membrane is applied from the lower edge of the roof, extending up the roof a distance of 24 inches inside the exterior wall line of the building. The membrane must be lapped a minimum of 3 inches on horizontal seams and 6 inches on vertical seams. Flashings around protrusions must be installed over the underlayment.





The roof covering may be installed immediately following the underlayment application, and the underlayment must be covered within the time designated in the report holder's published installation instructions.

6.0 CONDITIONS OF USE

6.1 Installation must comply with this Research Report, the manufacturer's published installation instructions, and the applicable Code. In the event of a conflict, this report governs.

6.2 Installation is limited to use with approved mechanically attached roof covering systems.

6.3 Installation is limited to installations where the roof covering does not involve hot asphalt or coal-tar pitch.

6.4 Installation is limited to roofs with slope of 2:12 (17%) or greater.

6.5 Attic ventilation must be provided in accordance with the building design and applicable Code since there are no requirements to evaluate vapor permeability of the underlayments.

6.6 Use of FelTex® SA300 underlayment is limited to structures where non-classified roof coverings are permitted or as a component of a classified roofing assembly when specifically recognized as such in a listing approved by the Code official.

6.7 Use of FelTex® SA300 underlayment is limited to plywood and OSB substrates.

6.8 The roofing underlayments are manufactured under a quality control program with inspections by Intertek Testing Services NA, Inc.

7.0 SUPPORTING EVIDENCE

7.1 Reports of tests in accordance with ASTM E108.

7.2 Data in accordance with the ICC-ES Acceptance Criteria for Roof Underlayments (AC188), dated February

2012 (editorially revised December 2015), for CoverPro® 1000, CoverPro® 2000, CoverPro® 3000, FelTex®, FelTex® SA300 underlayments.

7.3 Data in accordance with ICC-ES Acceptance Criteria for Self-adhered Roof Underlayments for Use as Ice Barriers (AC48), dated February 2012 (editorially revised December 2015), for FelTex® SA300 underlayment.

7.4 Intertek Listing Report "System Components Synthetic Roofing Underlayments", on the [Intertek Directory of Building Products](#).

8.0 IDENTIFICATION

The underlayments are identified with the report holder's name, telephone number, the product name, the Intertek Mark as shown below, and the Code Compliance Research Report number (CCRR-0310).



9.0 OTHER CODES

This section is not applicable.

10.0 CODE COMPLIANCE RESEARCH REPORT USE

10.1 Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

10.2 Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.

10.3 Reference to the <https://bpdirectory.intertek.com> is recommended to ascertain the current version and status of this report.





TABLE 1 - PROPERTIES EVALUATED

PROPERTY	2021 IBC SECTION ¹	2021 IRC SECTION ¹
Physical Properties	104.11, 1506 and 1507	R104.11, R904 and R905
Ice Barrier	1507	R905
Fire Classification	1505	R902.1

¹ Referenced sections apply to the 2021 IBC and IRC

This Code Compliance Research Report ("Report") is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



545 E. Algonquin Road • Arlington Heights • Illinois • 60005
[intertek.com/building](https://www.intertek.com/building)

