

Issue Date: 12-30-2020
Revision Date: 12-05-2025
Renewal Date: 12-31-2026

DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION
Section: 07 21 00 – Thermal Insulation
Section: 07 21 19 – Foamed-In-Place Insulation

REPORT HOLDER:

Xcelus Building Systems, Inc.
4400 MacArthur Blvd., Suite 101
Washington, DC 20007
(800) 205-6131
www.xcelusbuildingsystems.com

REPORT SUBJECT:

Xcelus XLS 500, XLS 450-NM, XLS 200, and XLS 2000 Spray-applied Polyurethane Insulation

1.0 SCOPE OF EVALUATION

1.1 This Research Report addresses compliance with the following Codes:

- 2024, 2021, 2018 *International Building Code*® (IBC)
- 2024, 2021, 2018 *International Residential Code*® (IRC)
- 2024, 2021, 2018 *International Energy Conservation Code*® (IECC)

NOTE: This report references the most recent edition of the Codes cited. Section numbers in earlier versions of the Codes may differ.

1.2 The insulations have been evaluated for the following properties (see Table 1):

- Physical properties
- Surface-burning characteristics
- Thermal resistance
- Air permeance

1.3 The insulations have been evaluated for the following uses (see Table 1):

- Use as a nonstructural thermal insulating material on or in interior and exterior walls, floors, ceilings and the underside of roofs
- Use as air-impermeable insulations
- Alternative to Code-prescribed thermal barriers

- Alternative to Code-prescribed ignition barriers
- Use in Type I, II, III, IV, and V construction (IBC) and buildings regulated under the IRC

2.0 STATEMENT OF COMPLIANCE

XLS 500, XLS 450-NM, XLS 200, and XLS 2000 insulations comply with the Codes listed in Section 1.1, for the properties stated in Section 1.2, and uses stated in Section 1.3, when installed as described in this report, including the Conditions of Use stated in Section 6.0.

2.1 2024 IBC and IRC Evaluation Reports: The Intertek CCRR is an *Evaluation Report* for approval of an alternate material, design, or method of construction in accordance with Section 104.2.3.6.1 of the 2024 IBC and Section R104.2.2.6.1 of the 2024 IRC.

3.0 DESCRIPTION

3.1 XLS 500, XLS 450-NM, XLS 200 and XLS 2000: The insulations are two-component spray-applied polyurethane foam plastic, produced in the field by combining a polymeric isocyanate (A component) with a resin (B component). The insulation liquid components are supplied in 55-gallon drums and must be stored at temperatures between 65°F and 85°F. The A and B components have a shelf life of six months when stored in factory-sealed containers at these temperatures.

XLS 500 and XLS 450-NM have a nominal density of 0.5 pcf. XLS 200 and XLS 2000 have a nominal density of 2 pcf.

3.2 DC315 Intumescent Coating: DC315 intumescent coating, manufactured by International Fireproof Technology, Inc., is a water-based coating supplied in 5-gallon pails and 55-gallon drums. The coating material has a shelf life of 24 months when stored in factory-sealed containers at a temperature between 41°F and 95°F. DC315 complies with ICC-ES AC456 and is recognized in ICC-ES ESR-3702.



3.3 ICP F10E Intumescent Coating: ICP F10E intumescent coating, manufactured by ICP Construction, is a water-based coating supplied in 5-gallon pails and 55-gallon drums. The coating material has a shelf life of 12 months when stored in factory-sealed containers at a temperature between 45°F and 95°F. The coating is recognized in ICC-ES ESR-3997 for compliance with ICC-ES AC456.

3.4 Flame Control 60/60A Intumescent Coating: Flame Control 60/60A is a water-based intumescent coating manufactured by Flame Control Coatings, LLC. The coating is supplied in 5-gallon pails and 55-gallon drums and has a shelf life of 12 months when stored in factory sealed containers at temperatures above 50°F. The coating is recognized in IAPMO UES ER-0596 for compliance with ICC-ES AC456.

3.5 No-Burn® ThB Spray Seal Intumescent Coating: No-Burn® ThB Spray Seal™ intumescent coating, manufactured by No Burn, Inc., is a white, water-based latex coating, supplied in 5-gallon pails and 55-gallon drums. The coating material has a shelf life of 12 months when stored in factory-sealed containers at a temperature between 40°F and 90°F. The coating is recognized in IAPMO UES ER-0305 for compliance with ICC-ES AC456.

4.0 PERFORMANCE CHARACTERISTICS

4.1 Surface-burning characteristics: The insulations, at a maximum thickness of 4 inches and the nominal densities stated in Section 3.1 of this report, have a flame-spread index of 25 or less and a smoke-developed index of 450 or less when tested in accordance with ASTM E84. Based on large scale tests in accordance with NFPA 286 and ICC-ES AC377 Appendix X, the insulations can be installed at greater thicknesses as described in Sections 5.3 and 5.4. When the insulations are separated from the interior occupied space of the building with minimum 1/2-inch-thick gypsum board, the maximum insulation thickness is not limited. Under the IRC, a thermal barrier of minimum 23/32-inch-thick wood structural panel is also permitted, and the maximum insulation thickness is not limited.

4.2 Thermal Resistance: The thermal resistance of the insulations is shown in Table 2.

4.3 Air Permeability: XLS 2000, at a minimum thickness of 1-1/2 inches, XLS 200 at a minimum thickness of 1-inch, XLS

450-NM at a minimum thickness of 3-1/2 inches, and XLS 500, at minimum thickness of 3 inches, are considered air-impermeable insulations in accordance with IBC Section 1202.3 or IRC Sections R202 and R806.5 and are considered an air barrier material complying with IECC Section C402.6.2.3.1, based on testing in accordance with ASTM E2178.

4.4 Vapor Permeance:

4.4.1 XLS 2000 has a vapor permeance of 0.83 perms when applied at a minimum thickness of 1-inch and may be used where a Class II vapor retarder is required.

4.4.2 XLS 200 has a vapor permeance of 0.96 perms when applied at a minimum thickness of 2-inches and may be used where a Class II vapor retarder is required.

4.4.3 XLS 450-NM has a vapor permeance of less than 10 perms when applied at a minimum thickness of 2 inches and may be used where a Class III vapor retarder is required.

5.0 INSTALLATION

5.1 General: The insulations must be installed in accordance with the manufacturer's published installation instructions, the applicable Code, and this Research Report. A copy of the manufacturer's instructions must be available on the jobsite during installation.

5.2 Application: The insulations are spray-applied on the jobsite using a volumetric positive displacement pump as identified in the manufacturer's application instructions. The insulations must not be used in areas that have a maximum in-service temperature of greater than 180°F. The insulations must not be used in electrical outlet or junction boxes or in contact with water, rain, or soil. The insulations must not be sprayed onto a substrate that is wet or covered with frost or ice, loose scales, rust, oil, or grease. The insulations must be protected from the weather during and after application.

XLS 500 must be applied when the ambient temperature is greater than 0°F and may be applied to the intended thickness, with each pass being a maximum of 12-inches thick. Where multiple passes are required, no cure time between passes is required.





XLS 450-NM may be applied to the intended thickness, with each pass being a maximum of 12-inches thick. Where multiple passes are required, no cure time between passes is required.

XLS 200 must be applied when the ambient temperature is greater than 32°F and may be applied in passes having a maximum thickness of 2 inches per pass. When multiple passes are required, subsequent passes can be sprayed once the core temperature drops below 100°F

XLS 2000 must be applied when the ambient temperature is greater than 14°F and may be applied in passes having a maximum thickness of 4 inches per pass. When multiple passes are required, subsequent passes can be sprayed once the core temperature drops below 100°F.

5.3 Thermal Barrier:

5.3.1 Application with a Prescriptive Thermal Barrier: The insulations must be separated from the interior living space of the building by an approved thermal barrier of 1/2-inch-thick gypsum board or an equivalent 15-minute thermal barrier complying with, and installed in accordance with, IBC Section 2603.4 or IRC Section R303.4, as applicable. Exceptions are provided in Sections 5.3.2 and 5.4.

When the insulations are separated from the interior living space of the building with minimum 1/2-inch-thick gypsum board, the maximum thickness is not limited. Under the IRC, a thermal barrier of 23/32-inch-thick wood structural panel is also permitted, and the maximum insulation thickness is unlimited.

5.3.2 Application without a Prescriptive Thermal Barrier: XLS 2000 and XLS 450-NM may be installed without the 15-minute thermal barrier prescribed in IBC Section 2603.4 and IRC Section R303.4, when installed as described in this section and in Table 3.

The coating must be applied over the insulation in accordance with the coating manufacturer's instructions and this report. Surfaces to be coated must be dry, clean, and free of dirt, loose debris and other substances that could interfere with adhesion of the coating. The coating is applied with low-pressure airless spray equipment.

5.4 Attics and Crawl Spaces: The insulations may be applied in attics and crawl spaces as described in either 5.4.1 or 5.4.2. When the insulation is installed in an attic or crawlspace in accordance with this section, a thermal barrier is not required between the insulation and the attic or crawl space but is required between the insulation and the interior living space. Attics and crawl spaces must be ventilated in accordance with the applicable Code.

5.4.1 Application with a Prescriptive Ignition Barrier: When the insulations are installed within attics and crawl spaces where entry is made only for service of utilities, the ignition barrier must be installed in accordance with IBC Section 2603.4.1.6, or IRC Section R303.5.3 or R303.5.4, as applicable. The ignition barrier must be consistent with the requirements for the type of construction required by the applicable Code and must be installed in a manner so the foam plastic insulation is not exposed.

5.4.2 Application without a Prescriptive Ignition Barrier: XLS 2000, XLS 450-NM and XLS 200 may be installed in attics and crawl spaces without the ignition barrier prescribed in IBC Section 2603.4.1.6 and IRC Sections R303.5.3 and R303.5.4, subject to the following conditions:

- a. Entry to the attic or crawl space is only to service utilities, and no storage is permitted.
- b. There are no interconnected attic or crawl space areas.
- c. Air in the attic or crawl space is not circulated to other parts of the building.
- d. Under-floor (crawl space) ventilation is provided when required by IBC Section 1202.4 or IRC Section R408.1, as applicable.
- e. Attic ventilation is provided when required by IBC Section 1202.2.1 or IRC Section R806, except when air-impermeable insulation is permitted in unvented attics in accordance with IBC Section 1202.3 or IRC Section R806.5.
- f. Combustion air is provided in accordance with IMC (International Mechanical Code) Section 701.

The insulation may be spray-applied to the underside of the roof sheathing and/or rafters in attics; the underside of wood floors in crawl spaces; and to vertical surfaces in both attics and crawl spaces, as described in this section and in Table 4.





The coating must be applied over the insulation in accordance with the coating manufacturer's instructions and this report. Surfaces to be coated must be dry, clean, and free of dirt, loose debris and other substances that could interfere with adhesion of the coating. The coating is applied with low-pressure airless spray equipment.

5.4.3 Use on Attic Floors: The insulations may be applied between and over the joists in attic floors to a maximum thickness as noted below with no coating or covering.

- XLS 2000 – 10 inches
- XLS 200 – 6 inches
- XLS 500 – 12 inches
- XLS 450-NM – 12 inches

The insulation must be separated from the interior occupied space by an approved thermal barrier.

5.4.4 Unvented Attics: In unvented attics conforming with IBC Section 1202.3 or IRC Section R806.5, the XLS 500 and XLS 450-NM insulations may be left exposed to the attic without a prescriptive ignition barrier or an intumescent coating, to a maximum thickness of 18 inches and a minimum thickness of 3 inches, subject to the following conditions:

- a. Entry to the attic is only to service utilities, and no storage is permitted.
- b. There are no interconnected attic areas.
- c. Air in the attic is not circulated to other parts of the building.
- d. Combustion air is provided in accordance with IMC (International Mechanical Code) Section 701.
- e. A downward opening attic hatch is required. The hatch shall remain closed at all times except for when servicing of utilities is required. The hatch shall be able to be opened freely without disengaging a latching or locking mechanism.
- f. The maximum uniform pressure required to open the downward opening attic hatch shall be less than 10 psf. The performance of the downward opening hatch is outside the scope of this evaluation report, but adequate information shall be provided to the Code official to demonstrate that this requirement has been satisfied. For field verification, the force required to open the downward opening hatch, when measured from the edge of the downward opening hatch opposite the

hinges shall not exceed the value calculated using the equation below:

$$F_{open} (\text{lbf}) \leq \text{Hatch Width (ft.)} \times \text{Hatch Length (ft.)} \times 5 \text{ lbf/sf}$$

g. An installation certificate with the following information shall be posted at each entrance to the attic:

- Product name and installation thickness
- Manufacturer name, address and contact information
- Installation contractor name, address and contact information
- Attestation that the product has been installed in accordance with the manufacture's installation instructions and the requirements of the CCRR
- A notice that the certificate is not to be removed or altered
- A list of limitations for the space including the following:
 - Entry to the space is only to service utilities and no storage is permitted
 - The hatch shall remain closed at all times except for when servicing of utilities is required. No locks or latches that would prevent the hatch from opening freely may be added at the hatch
 - FIRE SAFETY WARNING: If hot work (welding/cutting) is required to be performed, all necessary procedures, precautions and limitations must be observed in accordance with OSHA 1926, Subpart J, Standard 1926.352 requirements for hot work performed in the vicinity of combustible materials
 - Notification that the space has been designed and constructed / installed as an unvented attic assembly; introduction of any penetrations to the exterior or alterations to the insulation shall be designed by a registered design professional. The design of the change shall be submitted to the local Code official for approval, as required by the local jurisdiction.

For items penetrating the roof deck or walls, such as skylight wells or vents, the annular space must be covered with a minimum of 3 inches of insulation.

5.4.5 Exterior Walls in Types I, II, III, and IV Construction: XLS 500 and XLS 2000 may be installed in or on exterior walls of building Types I, II, III and IV construction complying with IBC Section 2603.5 and as described in Tables 5A and 5B.





Maximum permitted thickness of foam plastic is specified in Tables 5A and 5B.

6.0 CONDITIONS OF USE

6.1 Installation must comply with this Research Report, the manufacturer's published installation instructions, and the applicable Code. In the event of a conflict, this report governs.

6.2 The insulation must be separated from the interior occupied space of the building by a thermal barrier as described in Section 5.3, except as described in Section 5.3.2 and 5.4.

6.3 The insulation must not exceed the thicknesses noted in Sections 4.1, 5.3, and 5.4, as applicable.

6.4 XLS 500 and XLS 450-NM may be installed in unvented attics without a prescriptive ignition barrier or intumescent coating, subject to the conditions noted in Section 5.4.4.

6.5 Use of the insulation in areas where the probability of termite infestation is "very heavy" must be in accordance with IRC Section R305.4 or IBC Section 2603.8, as applicable.

6.6 Except as noted in Section 4.4, walls in which the insulation is applied must include a vapor barrier complying with the Code.

6.7 Jobsite certification and labeling of the insulation must comply with IRC Section N1101.10, N1101.14 and IECC Sections C303.1 or R303.1 and R401.3, as applicable.

6.8 The insulation products are manufactured under a quality control program with inspections by Intertek Testing Services NA, Inc.

7.0 SUPPORTING EVIDENCE

7.1 Reports of tests in accordance with ASTM E84, ASTM E96, ASTM E970, ASTM E2178, ASTM E283, and NFPA 285, NFPA 286 and US-FTC CFR Title 16 Part 460.

7.2 Data in accordance with the ICC-ES Acceptance Criteria for Spray-applied Foam Plastic Insulation (AC377), dated February 2023, including reports of tests in accordance with Appendix X and Appendix U.

7.3 Data in accordance with ICC 1100 (2019).

7.4 Research Reports for evaluation of data in accordance with ICC-ES Acceptance Criteria for Fire-protective Coatings Applied to Spray-applied Foam Plastic Insulation Installed without a Code-prescribed Thermal Barrier (AC456), dated October 2015.

7.5 Intertek Listing Report "Xcelus XLS 500, XLS 450-NM, XLS 200, and XLS 2000 Spray-applied Polyurethane Insulation", on the [Intertek Directory of Building Products](#).

8.0 IDENTIFICATION

The A and B components of the insulations described in this Research Report are identified with the report holder's name (Xcelus Building Systems, Inc.), address and telephone number; the product name; use instructions; the flame-spread and smoke-developed indices; the lot number; the Intertek Mark as shown below; and the Code Compliance Research Report number (CCRR-0397).



9.0 OTHER CODES

This section is not applicable.

10.0 CODE COMPLIANCE RESEARCH REPORT USE

10.1 Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

10.2 Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.

10.3 Reference to the <https://bpdirectory.intertek.com> is recommended to ascertain the current version and status of this report.





TABLE 1 – PROPERTIES EVALUATED

| PROPERTY | 2024 IBC SECTION ¹ | 2024 IRC SECTION ¹ | 2024 IECC SECTION ¹ |
|---|-------------------------------|-------------------------------|--------------------------------|
| Physical properties | 2603.1.1 | Not required | Not required |
| Surface-burning characteristics | 2603.3 | R303.3 | Not applicable |
| Thermal barrier/ignition barrier | 2603.4 | R303.4 | Not applicable |
| Air permeability | 1202.3 | R806.5 | C402.6 |
| Thermal resistance | 1301 | N1101.10 N1102 | C303.1 R303.1 |
| Exterior Walls in Types I-IV Construction | 2603.5 | Not Applicable | Not applicable |

¹ Section numbers may be different for earlier versions of the International Codes.

TABLE 2 – THERMAL RESISTANCE

| THICKNESS (IN.) | R-VALUE (°F.FT ² .H/BTU) ^{1, 2, 3, 4} | | | |
|-----------------|---|------------|---------|----------|
| | XLS 500 | XLS 450-NM | XLS 200 | XLS 2000 |
| 1 | 3.9 | 4.1 | 6.9 | 7.6 |
| 3.5 | 13 | 13 | 23 | 26 |
| 16 | 59 | 59 | 107 | 119 |

¹R-values are calculated based on tested K values at 1- and 3-1/2-inch thicknesses

²R-values may be interpolated between 1 and 3-1/2 inches

³Above 3-1/2 inches, R-values may be calculated as follows:

- XLS 500: R-values are calculated using R=3.67/ inch
- XLS 450-NM: R-values are calculated using R=3.67/inch
- XLS 200: R-values are calculated using R=6.70/inch
- XLS 2000: R-values are calculated using R=7.43/inch

⁴R-values greater than 10 are rounded to the nearest whole number



TABLE 3 – USE OF INSULATION WITHOUT A PRESCRIPTIVE THERMAL BARRIER

| INSULATION TYPE | MAXIMUM THICKNESS (IN.) (WALL CAVITIES) | MAXIMUM THICKNESS (IN.) (CEILINGS, UNDERSIDE OF ROOF SHEATHING / RAFTERS & FLOORS) | INTUMESCENT COATING MINIMUM THICKNESS & TYPE (APPLIED TO ALL FOAM SURFACES) | MINIMUM APPLICATION RATE OF THE INTUMESCENT COATING | MAY BE LEFT EXPOSED AS AN INTERIOR FINISH | TESTS SUBMITTED |
|-----------------|---|--|---|---|---|-----------------|
| XLS 2000 | 7-1/4 | 7-1/4 | DC315 18 wet mils | 1.13 gal / 100 ft ² | Yes | NFPA 286 |
| | 8 | 12 | DC315 20 wet mils | 1.28 gal / 100 ft ² | Yes | NFPA 286 |
| | 6 | 10 | ICP F10E 14 wet mils | 0.86 gal / 100 ft ² | Yes | NFPA 286 |
| | 8 | 10 | Flame Control 60/60A 14 wet mils | 0.87 gal / 100 ft ² | Yes | NFPA 286 |
| | 8 | 10 | No-Burn Plus ThB 14 wet mils | 0.87 gal / 100 ft ² | Yes | NFPA 286 |
| XLS 500 | 8 | 12 | DC315 14 wet mils | 0.90 gal / 100 ft ² | Yes | NFPA 286 |
| XLS 450-NM | 10 | 14 | DC 315 14 wet mils | 0.90 gal / 100 ft ² | Yes | NFPA 286 |
| | 10 | 14 | No-Burn ThB Spray Seal 14 wet mils | 0.87 gal/100ft ² | Yes | NFPA 286 |
| XLS 450-NM | 10 | 14 | Flame Control 60-60A 16 wet mils | 1.00 gal / 100 ft ² | Yes | NFPA 286 |



TABLE 4 – USE OF INSULATION IN ATTICS AND CRAWL SPACES WITHOUT A PRESCRIPTIVE IGNITION BARRIER

| INSULATION TYPE | MAXIMUM THICKNESS (IN) (WALL CAVITIES & ATTIC FLOORS) | MAXIMUM THICKNESS (IN) (UNDERSIDE OF ROOF SHEATHING / RAFTERS & FLOORS) | INTUMESCENT COATING MINIMUM THICKNESS & TYPE (APPLIED TO ALL FOAM SURFACES) | MINIMUM APPLICATION RATE OF THE INTUMESCENT COATING | TESTS SUBMITTED |
|-----------------|---|---|---|---|-----------------|
| XLS 2000 | 6 | 10 | No coating required | NA | Appendix X |
| XLS 200 | 6 | 6 | No coating required | NA | Appendix X |
| XLS 500 | 8 | 12 | DC315 4 wet mils | 0.25 gal / 100 ft ² | Appendix X |
| XLS 450-NM | 8 | 12 | DC315 4 wet mils | 0.25 gal / 100 ft ² | Appendix X |



TABLE 5A – NFPA 285 COMPLYING WALLS – XLS 500, XLS 450-NM and XLS 2000 in Wall Cavities

| WALL COMPONENT | MATERIALS |
|--|--|
| Base Wall System – Use either 1, 2, or 3 | <ol style="list-style-type: none"> 1. Concrete Wall 2. Concrete Masonry Wall 3. One layer of min. 5/8-in. thick Type X gypsum wallboard installed on the interior side of min. 3-5/8-in. deep, minimum 25-GA thick steel studs spaced a maximum 24-in. on center. Lateral bracing installed minimum every 4-ft vertically or as required. Wall stud cavities shall be filled at each floor line with minimum 4 pcf mineral wool friction fit between steel studs. |
| Perimeter Fire Barrier System | Perimeter fire barrier system complying with IBC Section 715.4 shall be installed, as applicable, to fill the void between the edge of the concrete floor slab and the interior surface of the exterior wall assembly. |
| Wall Cavity Insulation | Full wall stud cavity depth or less of insulation applied using exterior sheathing as the substrate and covering the width of the cavity and the inside of the steel wall stud framing flange. Maximum thickness of XLS 500 or XLS 450-NM is 5-1/2 inches; maximum thickness of XLS 2000 is 3-5/8 inches. |
| Exterior Sheathing | Min. 5/8-in thick Type X exterior type gypsum sheathing complying with ASTM C1177 |
| Exterior Wall Covering – Use either 1, 2, or 3 | <ol style="list-style-type: none"> 1. Any non-combustible exterior wall covering material using any standard installation technique. 2. Any non-combustible exterior wall covering system with a combustible WRB that has been successfully tested in accordance with NFPA 285. 3. Any combustible exterior wall covering system with or without WRB that has been successfully tested in accordance with NFPA 285. |





TABLE 5B – NFPA 285 COMPLYING WALLS – XLS 500 and XLS 2000 on Exterior Sheathing

| WALL COMPONENT | MATERIALS |
|---|--|
| Base Wall System – Use either 1, 2, or 3 | <ol style="list-style-type: none"> 1. Concrete Wall 2. Concrete Masonry Wall 3. One layer of min. 5/8-in. thick Type X gypsum wallboard installed on the interior side of 3-5/8-in. deep, minimum 20-GA thick steel studs spaced a maximum 24-in. on center. Lateral bracing installed minimum every 4-ft vertically or as required. Wall stud cavities shall be filled at each floor line with minimum 4 pcf mineral wool friction fit between steel studs. |
| Perimeter Fire Barrier System | Perimeter fire barrier system complying with IBC Section 715.4 shall be installed, as applicable, to fill the void between the edge of the concrete floor slab and the interior surface of the exterior wall assembly. |
| Exterior Sheathing | Min. 5/8-in thick Type X exterior type gypsum sheathing complying with ASTM C1177 |
| Exterior Insulation – Use either 1 or 2 | <ol style="list-style-type: none"> 1. Maximum 5-1/2-in. (nominal) thickness of XLS 500 or XLS 450-NM applied to the exterior side of the exterior sheathing. 2. Maximum 3-in. (nominal) thickness of XLS 2000 applied to the exterior side of the exterior sheathing. |
| Exterior Wall Covering – Use either 1, 2, 3, or 4 | <ol style="list-style-type: none"> 1. Any non-combustible exterior wall covering material using any standard installation technique. 2. Install nominal 4-in. thick clay brick or veneer with max. 2-in. air gap, with brick ties/anchors spaced max. 16-in. on center vertically and max. 24-in. on center horizontally, aligned with framing. 3. Any non-combustible exterior wall covering system with a combustible WRB that has been successfully tested in accordance with NFPA 285. 4. Any combustible exterior wall covering system with or without WRB that has been successfully tested in accordance with NFPA 285. |

This Code Compliance Research Report (“Report”) is for the exclusive use of Intertek’s Client and is provided pursuant to the agreement between Intertek and its Client. Intertek’s responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



545 E. Algonquin Road • Arlington Heights • Illinois • 60005
intertek.com/building



PCA-101