

Issue Date: 09-14-2021
Revision Date: 06-05-2026
Renewal Date: 10-31-2026

DIVISION: 07 00 00 – THERMAL AND MOISTURE PROTECTION

Section: 07 30 05 – Roofing Felt and Underlayment

REPORT HOLDER:

Levi's Building Components LLC

400 Burkholder Drive,

Ephrata, PA 17522

USA

(717) 868-7175

www.levisbuildingcomponents.com

REPORT SUBJECT:

Roloshield Prime (ROLOPRIME SA) Self-adhered Roofing Underlayment

1.0 SCOPE OF EVALUATION

1.1 This Research Report addresses compliance with the following Codes:

- 2024, 2021, and 2018 *International Building Code*® (IBC)
- 2024, 2021, and 2018 *International Residential Code*® (IRC)
- 2024 *International Wildlife-Urban Interface Code* (IWUIC)
- 2023 and 2020 *Florida Building Code* (FBC) (See Section 8.1)
- 2022 *California Building Code* (CBC) and 2022 *California Residential Code* (CRC) (See Section 8.2)
- 2023 *City of Los Angeles Building Code* (LABC) and 2023 *City of Los Angeles Residential Code* (LARC) (See Section 8.3)

1.2 The underlayment has been evaluated for the following properties (see Table 1):

- Physical Properties
- Fire Classification
- Ice Barrier

1.3 The underlayment has been evaluated for the following uses (see Table 1):

- Use in the field of the roof where self-adhering roof underlayments complying with ASTM D1970 are required as specified in Chapter 15 of the IBC, and Chapter 9 of the IRC.
- Use in areas of the roof required by IBC Section 1507 or IRC Section R905 to have an ice barrier roof underlayment, when installed as noted in Section 4.3.
- Use as a component of classified assemblies when installed as described Section 4.2.
- Under the 2024 IWUIC, Section 504.2, Roloshield Prime self-adhered underlayment may be used on buildings requiring Class 1 ignition resistant construction in wildland-urban interface areas, when installed as part of an assembly described in Table 2 or this report.

2.0 STATEMENT OF COMPLIANCE

Roloshield Prime self-adhered underlayment complies with the Codes listed in Section 1.1, for the properties stated in Section 1.2, and uses stated in Section 1.3, when installed as described in this report, including the Conditions of Use stated in Section 5.0.

3.0 DESCRIPTION

Roloshield Prime is a 45-mil thick self-adhered synthetic underlayment comprised of a synthetic facer (a multilayer laminated non-woven and woven scrim), a polymer-modified bitumen adhesive and a split release liner. The underlayment has a 3 inch edge lap of adhesive, which is protected by an end-revealer. This end-revealer is removed to ensure secure adhesive adhesion in the overlapping areas. The underlayment is available in custom colors and in rolls of 36 inches wide by 67 feet long, and 36 inches wide by 72 feet long.



4.0 INSTALLATION

4.1 General: Roloshield Prime underlayment must be installed in accordance with the manufacturer's published installation instructions, the applicable Code, and this Research Report. A copy of the manufacturer's instructions must be available on the jobsite during installation.

4.2 Fire Classification: When installed in accordance with the assembly described in Table 2 of this report, the roofing underlayment meets Class A fire classification per ASTM E108. Additionally, the underlayment may be used as a component of a classified roof assembly when specifically recognized as such in a Listing approved by the Code official. The underlayment may also be used as an alternative to the underlayments specified in the Code for roof coverings permitted under the Exceptions to IBC Section 1505.2 and IRC Section R902.1, and may be used where non-classified roofing is permitted in IBC Section 1505.5.

4.3 Application: The roof deck must be in proper condition to ensure adhesion. Installation is limited to solid-sheathed decks of plywood substrates. The membrane is self-adhered to the substrate after the release liner is removed.

The membrane must be lapped a minimum of 3 inches on horizontal seams and 6 inches on vertical seams. Flashings around protrusions must be installed under the underlayment.

When used as an ice barrier, the membrane is applied from the lower edge of the roof, extending up the roof a distance of 24 inches inside the exterior wall line of the building.

The underlayment may be installed with the roof coverings specified in IBC Table 1507.1.1(1) and IRC Table R905.1.1(1), where ASTM D1970-compliant underlayments are permitted. The underlayment must be installed in accordance with IBC Table 1507.1.1(2) and IRC Table R905.1.1(2) and fastened in accordance with IBC Table 1507.1.1(3) and IRC Table R905.1.1(3).

When installed as described in Table 2 of this report, the roof assemblies comply with IWUIC Section 504.2 and

may be used on buildings requiring Class 1 ignition-resistant construction in wildland-urban interface areas.

The roof covering may be installed immediately following the underlayment application, and the underlayment must be covered within the time designated in the report holder's published installation instructions.

5.0 CONDITIONS OF USE

5.1 Installation must comply with this Research Report, the manufacturer's published installation instructions, and the applicable Code. In the event of a conflict, this report governs.

5.2 Installation is limited to use with approved mechanically attached roof covering systems.

5.3 Installation is limited to roof systems that do not involve hot asphalt or coal-tar pitch.

5.4 Installation is limited to roofs with slope of 2:12 (17%) or greater.

5.5 Attic ventilation must be provided in accordance with the applicable Code since there are no requirements to evaluate vapor permeability of the underlayments.

5.6 Roloshield Prime underlayment is manufactured under a quality control program with inspections by Intertek Testing Services NA, Inc.

6.0 SUPPORTING EVIDENCE

6.1 Reports of tests in accordance with ASTM D1970-18.

6.2 Data in accordance with the ICC-ES Acceptance Criteria for Roof Underlayments (AC188), dated February 2012 (editorially revised December 2015).

6.3 Reports of tests in accordance with FRSA/TRI Florida High Wind Concrete and Clay Tile Installation Manual (7th Edition).

6.4 Intertek Listing Report "Levi's Synthetic Roofing Underlayments", on the [Intertek Directory of Building Products](#).





7.0 IDENTIFICATION

Roloshield Prime self-adhered roofing underlayment is identified with the manufacturer's name (Levi's Building Components), address and telephone number, the product name (Roloshield Prime), the Intertek Mark as shown below, and the Code Compliance Research Report number (CCRR-0429).



8.0 OTHER CODES

8.1 Florida Building Code: Roloshield Prime underlayment described in Sections 2.0 to 7.0 of this report complies with the 2023 and 2020 *Florida Building Code – Building* and the 2023 and 2020 *Florida Building Code – Residential*, subject to the following conditions:

8.1.1 For Use Outside HVHZ: The underlayment may be installed with roof coverings specified in FBC (Building) Section 1507.1.1 and FBC (Residential) Section R905.1.1, where ASTM D1970-compliant underlayments are permitted. The underlayment must be installed in accordance with FBC (Building) Section 1507 and FBC (Residential) R905.

- When installed as described in Table 2 of this report, the roof assembly meets Class A fire classification per ASTM E108. Additionally, the underlayment may be used as follows:
 - i. As a component of a classified roof assembly when specifically recognized as such in a Listing Report approved by the Code official.
 - ii. As an alternative to the underlayment specified in the Code for roof coverings permitted under Exceptions 1 - 4 to FBC (Building) Section 1505.2 and Exceptions 1 - 4 to FBC (Residential) Section R902.1.
 - iii. Where non-classified roofing is permitted in FBC (Building) Section 1505.5.
- The underlayment has an allowable design pressure of -127.5 psf when adhered directly to 19/32 in. thick plywood sheathing.

- The underlayment may be installed with clay and concrete tiles outside of the HVHZ when installed in accordance with *Florida Building Code – Building*, Section 1507.3.3 and *Florida Building Code – Residential*, Section R905.3.3. The tiles may be mechanically fastened or adhered with Tile Bond™ Roof Tile adhesive or Polyset® RTA-1 adhesive.

8.1.2 For Use Inside HVHZ: The underlayment may be installed with the roof coverings specified in FBC (Building) Section 1518, where ASTM D1970-compliant underlayments are permitted. The underlayment must be installed in accordance with the provisions of FBC (Building) Section 1518.

- When installed as described in Table 2 of this report, the roof assembly may be used where Class A fire classification is required in FBC (Building) Section 1516.2.1. Additionally, the underlayment may be used with roof coverings permitted under the Exception to FBC (Building) Section 1516.2.1.

Intertek is an approved evaluation entity and quality assurance entity pursuant to Florida Statute 553.842 – *Product Evaluation and Approval*.

8.2 California Building Code and California Residential Code:

8.2.1 Scope of the Evaluation: The Roloshield Prime underlayment was evaluated for compliance with the 2022 *California Building Code* and 2022 *California Residential Code*.

8.2.2 Conclusion: The Roloshield Prime underlayment described in Section 2.0 through 7.0 of this report complies with the 2022 *California Building Code* and 2022 *California Residential Code*, including use in the exterior design and construction of buildings located within the Wildland-Urban Interface Fire Area outlined under *California Building Code* Section 705A and *California Residential Code* Section R337.

8.3 City of Los Angeles Building Code and City of Los Angeles Residential Code:

8.3.1 Scope of the Evaluation: The Roloshield Prime roofing underlayment was evaluated for compliance with





the 2023 *City of Los Angeles Building Code* and 2023 *City of Los Angeles Residential Code*.

8.3.2 Conclusion: The Roloshield Prime roofing underlayment described in Section 2.0 through 7.0 of this report may be installed with the roof covering specified in LABC Section 1507 and LARC Section R905.1.1, where ASTM D1970-compliant underlayments are permitted. The underlayment must be installed in accordance with the provisions of LABC Section 1507 and LARC Section R905.

The underlayment may be used in the exterior design and construction of buildings located within the Wildland-Urban Interface Fire Area outlined under LABC Section 705A.

9.0 ODE COMPLIANCE RESEARCH REPORT USE

9.1 Approval of building products and/or materials can only be granted by a building official having legal authority in the specific jurisdiction where approval is sought.

9.2 Code Compliance Research Reports shall not be used in any manner that implies an endorsement of the product by Intertek.

9.3 Reference to the <https://bpdirectory.intertek.com> is recommended to ascertain the current version and status of this report.

This Code Compliance Research Report ("Report") is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Report. Only the Client is authorized to permit copying or distribution of this Report and then only in its entirety, and the Client shall not use the Report in a misleading manner. Client further agrees and understands that reliance upon the Report is limited to the representations made therein. The Report is not an endorsement or recommendation for use of the subject and/or product described herein. This Report is not the Intertek Listing Report covering the subject product and utilized for Intertek Certification and this Report does not represent authorization for the use of any Intertek certification marks. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



545 E. Algonquin Road • Arlington Heights • Illinois • 60005
intertek.com/building





TABLE 1 – PROPERTIES EVALUATED

PROPERTY	2024 IBC SECTION	2024 IRC SECTION	2023 FBC (BUILDING)	2023 FBC (RESIDENTIAL)	2022 CALIFORNIA BUILDING CODE SECTION	2022 CALIFORNIA RESIDENTIAL CODE SECTION	2024 IWUIC SECTION	2023 LABC SECTION (BUILDING)	2023 LARC SECTION (RESIDENTIAL)
Physical Properties	1506 and 1507	R904 and R905	1506, 1507.1.1, and 1515.1.4	R904, R905.1.1	1506 and 1507	R904 and R905	-	1507	R904 and R905
Fire Classification	1505	R902.1	1505	R902	1505 705A	R902.1 R337.5	504.2	1505 705A	R902.1 R337.5
Ice Barrier	1507	R905	N/A	N/A	1507	R905	-	1507	R905

NOTE: Section numbers may be different for earlier versions of the Codes.

TABLE 2 – FIRE CLASSIFICATION

CLASSIFICATION AND SLOPE	DECK	UNDERLAYMENT	ROOF COVERING
Class A 2:12 or greater	Minimum nominal 3/8 in. thick Code compliant exterior grade plywood	A single layer of Roloshield Prime underlayment installed using the products peel and stick backing.	Three-tab asphalt shingles Listed per ASTM D3462 with a minimum weight of 190 pounds per 100 square feet installed per manufacturer's installation instructions

